

EROSION CONTROL NOTES

1. In case of emergency call:

Project Manager: _____ at: (_____) _____

2. The understanding Civil Engineer will supervise erosion control work and certify that the system functions properly and is in accordance with the approved plans.
3. Devices shall not be moved or modified without the approval of the City Engineer or in an emergency, by the design of the Civil Engineer or designee.
4. All removable protective devices shown shall be in place at the end of each working day when the five (5) day rain probability forecast exceeds forty (40) percent. Forecast shall be received from broadcasts provided by the United States Weather Service.
5. After a rainstorm, all silt and debris shall be removed and the berms and desilting basins checked. The basins shall be pumped dry. Any grade slope surface protection measures damaged during a rainstorm shall also be immediately repaired. Failure to provide effective maintenance may result in penalties.
6. Graded areas around the tract perimeter, if applicable, must drain away from the face of the slope at the conclusion of each working day.
7. The contractor shall be responsible and shall take necessary precautions to prevent public trespass onto areas where impounded water creates a hazardous condition.
8. Areas shall be maintained in such state that fire access shall be maintained at all times (including access to neighboring properties).
9. Planting for slope protection shall be accomplished prior to rough grade release, unless a waiver of this requirement has been obtained from the City Engineer.
10. All lot pads shall be designed to drain to an acceptable location at a minimum of one (1) percent.
11. Devices shall be properly maintained in place until project completion. Damaged gravel bags must be replaced.
12. Build-up of silt around any desilters shall be periodically removed to the satisfaction of the City's Public Works Inspector. The contractor shall also be responsible for temporary storage of existing manhole covers, if applicable, until desilter use of manhole is complete.
13. A guard shall be posted on the site whenever the depth of water in any device exceeds eighteen (18) inches.
14. After a rainstorm, all silt and debris shall be removed from public drains or pipes, from drains or pipes of adjacent properties, and from all public properties and private streets.
15. For projects extending into subsequent rainy season, new temporary drainage and erosion control plans shall be submitted. These plans shall comply with all the above-mentioned requirements.
16. For developments greater than one (1) acre, developer shall submit a notice of intent to the State of California Water Resource Board in accordance with the requirements of the National Pollutant Discharge Elimination System Program and the Clean Water Act of 1990.
17. For all grading projects, developer must submit a Water Quality Management Plan to the City Engineer for review and approval in conjunction with the grading plans submittal.