

# IRRIGATION WATER NOTES

## ALL SIZES

### New Construction:

New Construction will have a separate meter service for irrigation connection per Standard # 413 and have a Reduced Pressure Principle Device installed.

**A billing account must be established immediately after meter is installed.**

### Upgrades to Existing Commercial / Industrial Landscaping:

If an approved backflow prevention device is not already installed, install a new Reduced Pressure (RP) principle device. The point of connection of the RP shall be at the meter box immediately behind the meter connection. The existing meter box must be large enough to accommodate a Jones J-1900W (or approved equal) locking ball valve and accessible by a turn off key. The meter box shall be installed per Standard # 413A. If the existing box is too small, a larger one shall be provided. Irrigation make up line shall be per Standard # 413A.