

MIDWAY CITY SANITARY DISTRICT SEWER NOTES

1. The sewer system as shown on the plans shall be constructed in accordance with the standard drawings and specifications of the Midway City Sanitary District.
2. Four-inch (4") VCP sewer house connections to be constructed from the sewer main to five (5) feet beyond the property line for each lot. The Developer shall furnish the sewer contractor with a "plot plan" indicating the location of the house connection for each lot. House connections shall be installed prior to paving of streets.
3. Standard specifications are available at the office of the Midway City Sanitary District, 14451 Cedarwood Avenue, Westminster, Ca 92683.
4. Midway City Sanitary District shall be notified at least two (2) days prior to commencing work. The phone number is (714) 893-3553.
5. Mainline sewer installation shall include (by Sewer Contractor) all necessary wyes, fittings and pertinent materials necessary. Where mainline sewer is installed adjacent to undeveloped property, wyes shall be installed as per instruction from Midway City Sanitary District's Inspector.
6. Sewer stationing does not necessarily coincide with street improvement stationing. Sewer station shall start with indicating 0+00.
7. House laterals at the end of main lines to be normal to centerline of main sewer. Mainline sewer to be extended where necessary. (Cul-de-sac sewers excepted.)
8. All pipe, pipe joints, and pipe fittings to be extra strength VCP meeting FEDERAL Specifications SSP-3616 with mechanical compression joints meeting A.S.T.M. Specifications C-425.
9. House laterals to be installed as closely as possible (without cutting tile) to the locations shown on the Improvement Plans.
10. Approved applicant is subject to paying all fees and granting the necessary easements to the Midway City Sanitary District and signing of Petition for Annexation.
11. The Registered Engineer signing the plans shall be responsible for determining the correct locations and elevations of the existing sewer facilities shown hereon prior to commencing work.
12. The sewer construction shall start at the connection to the existing sewer facility and proceed up grade.

APPROVED: **MIDWAY CITY SANITARY DISTRICT**