



CLASS "B" CONCRETE
SEE NOTE 2

CROSS-SECTION

NOTES:

1. ALL REMOVED AGGREGATE BASE SHALL BE REPLACED WITH CLASS "B" CONCRETE.
2. CONCRETE MAY BE CIRCULAR OR SQUARE IN SHAPE WITH A MINIMUM OF 12" BETWEEN EDGE OF CONCRETE AND LIP OF MANHOLE FRAME.
3. MANHOLES MAY BE ADJUSTED TO GRADE USING BRICK AND MORTAR OR PRECAST RINGS AT THE CONTRACTOR'S OPTION.

APPROVED:

Manuel V. Pousse
P.W. DIRECTOR / CITY ENGINEER

REVISED DATE: 5/15/08



City of Westminster
DEPARTMENT OF PUBLIC WORKS

STANDARD FOR
MANHOLE ADJUSTMENTS

STANDARD NUMBER

704