



IF PAVED, REPLACE PER STANDARD DRAWING #609

EXISTING GROUND

COMPACT TO A RELATIVE COMPACTION OF 90% MIN.

FORM WITH PLYWOOD OR SAND BAG IS ALLOWED

CONCRETE

USE:
 1 PART CEMENT
 3 PARTS SAND
 4 PARTS ROCK
 OR
 2,000 PSI / 28 DAY
 READY-MIX CONCRETE

BACKFILL

USE:
 3 SACKS CEMENT TO 1 YARD CLEAN SAND OR ALLUVIAL SOIL OR CLEAN, WELL PUDDLED MUD, (ROTARY OR BENTONITE).

NOTE:

ALL WORK SHALL COMPLY WITH HEALTH CODE AND HAVE APPROVAL OF COUNTY HEALTH OFFICER.

BOTTOM OF WELL

APPROVED:

William J. Russell
 P.W. DIRECTOR / CITY ENGINEER



City of Westminster
 DEPARTMENT OF PUBLIC WORKS

STANDARD NUMBER

ABANDONED
 WATER WELLS

602

REVISED DATE: 5/15/08