


CROSS SECTION OF C-900 PVC INSTALLED IN STEEL CASING

SIZE OF CASING REQUIRED C-900 PVC PIPE		
PIPE DIA.	CASING DIA.	WALL THICK
6 INCHES	14 INCHES	3/16 INCH
8 INCHES	18 INCHES	1/4 INCH
10 INCHES	18 INCHES	1/4 INCH
12 INCHES	20 INCHES	1/4 INCH



SIDE VIEW OF C-900 PVC PIPE ON SKIDS

APPROVED:

Marwan Yousef

P.W. DIRECTOR / CITY ENGINEER

REVISED DATE: 5/15/08



City of Westminster

DEPARTMENT OF PUBLIC WORKS

WATER MAIN
ENCASEMENT

STANDARD NUMBER

405