



DO NOT INSTALL IN VAULT

PROFILE VIEW
NOT TO SCALE

CONSTRUCTION NOTES

- ① BALL VALVES
- ② SOLDER 90° ELL
- ③ M.I.P. SOLDER ADAPTER
- ④ SOLDER UNION
- ⑤ TYPE "K" RIGED COPPER OR BRASS WRAPPED WITH 10 MIL POLYETHYLENE TAPE
- ⑥ CONCRETE SLAB SHALL BE C-560-3250 MIX
- ⑦ FLANGE - FLANGE 90°

GENERAL NOTES

- 1. METER SHALL BE PER CITY SANTDARD # 401 AND # 413
- 2. ALL NEW DEVELOPMENT REQUIRING A FIRE SERVICE SHALL HAVE A SEPARATE DEDICATED WATER LINE FOR IT.

APPROVED:

Maura Young
P.W. DIRECTOR / CITY ENGINEER



REVISED DATE: 5/15/08

City of Westminster
DEPARTMENT OF PUBLIC WORKS

**DOUBLE CHECK BACKFLOW
ASSEMBLY FIRE SERVICE
OR DOMESTIC 3/4" - 2 1/2"**

STANDARD NUMBER

415