

City of Westminster

8200 Westminster Boulevard, Westminster CA 92683 714.548.3254 www.westminster-ca.gov

Eligibility Checklist for Expedited Electric Vehicle Charging Station Permit: Non-Residential Buildings and Facilities

Type of Charging Station(s)	Power Levels (proposed circuit rating)	Chec	k one
Level 1	110/120 volt alternating current (VAC) at 15 or 20 Amps	5	
Level 2 - 3.3 kilowatt (kW) (low)	208/240 VAC at 20 or 30 Amps		
Level 2 – 6.6kW (medium)	208/240 VAC at 40 Amps		
Level 2 – 9.6kW (high)	208/240 VAC at 50 Amps		
Level 2 – 19.2kW (highest)	208/240 VAC at 100 Amps		
Other (provide detail):	Provide rating:		
Permit Application Requireme	ents:		
A. Does the application include E\	/CS manufacturer's specs and installation guidelines?	Υ	N
Electrical Load Calculation W	orksheet:		
A. Is an electrical load calculation worksheet included? (CEC 220)		Y	
B. Based on the load calculation worksheet, is a new electrical service panel upgrade required?			7
l redolled?			
	the electrical service panel upgrade?	Δ	
1) If yes, do plans include	the electrical service panel upgrade? ately sized for a continuous load of 125%?	Y Y	
1) If yes, do plans include C. Is the charging circuit appropri D. If charging equipment propose			
1) If yes, do plans include C. Is the charging circuit appropri D. If charging equipment propose Amps or higher, is a complete the single line diagram? Site Plan and Single Line Draw	ately sized for a continuous load of 125%? ed is a Level 2 – 9.6 kW station with a circuit rating of 50 d circuit card with electrical calculations included with	Y	
1) If yes, do plans include C. Is the charging circuit appropri D. If charging equipment propose Amps or higher, is a complete the single line diagram? Site Plan and Single Line Draw A. Is a site plan signed off by Plan	ately sized for a continuous load of 125%? ed is a Level 2 – 9.6 kW station with a circuit rating of 50 d circuit card with electrical calculations included with	Y	
1) If yes, do plans include C. Is the charging circuit appropri D. If charging equipment propose Amps or higher, is a complete the single line diagram? Site Plan and Single Line Draw A. Is a site plan signed off by Plant a single-line diagram includ 1) If mechanical ventilation requirements (CEC 625.5)	ately sized for a continuous load of 125%? ed is a Level 2 – 9.6 kW station with a circuit rating of 50 d circuit card with electrical calculations included with ving: anning Division and a separate electrical plan with	Y Y	
1) If yes, do plans include C. Is the charging circuit appropri D. If charging equipment propose Amps or higher, is a complete the single line diagram? Site Plan and Single Line Draw A. Is a site plan signed off by Place a single-line diagram includ 1) If mechanical ventilation	ately sized for a continuous load of 125%? ed is a Level 2 – 9.6 kW station with a circuit rating of 50 d circuit card with electrical calculations included with ving: anning Division and a separate electrical plan with ed with the permit application? requirements are triggered for indoor venting 52 (B)), is a mechanical plan included with the	Y Y Y	
1) If yes, do plans include C. Is the charging circuit appropri D. If charging equipment propose Amps or higher, is a complete the single line diagram? Site Plan and Single Line Draw A. Is a site plan signed off by Pla a single-line diagram includ 1) If mechanical ventilation requirements (CEC 625.5 permit application? B. Is the site plan fully dimension	ately sized for a continuous load of 125%? ed is a Level 2 – 9.6 kW station with a circuit rating of 50 d circuit card with electrical calculations included with ving: anning Division and a separate electrical plan with ed with the permit application? requirements are triggered for indoor venting 62 (B)), is a mechanical plan included with the	□ Y □ Y □ Y	
1) If yes, do plans include C. Is the charging circuit appropri D. If charging equipment propose Amps or higher, is a complete the single line diagram? Site Plan and Single Line Draw A. Is a site plan signed off by Pla a single-line diagram includ 1) If mechanical ventilation requirements (CEC 625.5 permit application? B. Is the site plan fully dimension 1) Showing location, size, ar	ately sized for a continuous load of 125%? ed is a Level 2 – 9.6 kW station with a circuit rating of 50 d circuit card with electrical calculations included with ving: anning Division and a separate electrical plan with ed with the permit application? requirements are triggered for indoor venting 62 (B)), is a mechanical plan included with the	Y Y Y Y	

Compliance with the California Electrical Code:

A. [Does the plan include EVCS manufacturer's specs and installation guidelines?	ПҮ	ПИ		
	Does the electrical plan identify the amperage and location of existing electrical	□Y	□N		
	service panel? 1) If you does the existing panel schedule show room for additional breakers?				
С	1) If yes, does the existing panel schedule show room for additional breakers? Is the charging unit rated more than 60 amps or more than 150V to ground?	Y Y	□ N		
<u> </u>	1) If yes, are disconnecting means provided in a readily accessible location in line of	Y	□N		
	site? (CEC 625.43)				
	Does the charging equipment have a Nationally Recognized Testing Laboratory (NRTL) approved listing mark? (UL 2202/UL 2200)	ΠY	ПИ		
E. If	f trenching is required, is the trenching detail called out?	ΠY	□N		
	 Is the trenching in compliance with minimum cover requirements for wiring methods or circuits? (18" for direct burial per CEC 300.5) 	ΠY	□N		
Cor	npliance with the California Green Building Standards Code (CGBSC):				
Α. [Do the CAL Green EV Readiness installation requirements apply to this project?	ΠY	□N		
	Do the plans demonstrate conformance with CGBSC Table 5.106.5.3.3 for the minimum required number of charging spaces?	ΠY	□N		
	2) Do the construction plans comply with the design requirements set forth in CGBSC 5.106.5.3.1 for single charging spaces or CGBSC 5.106.5.3.2 for multiple charging spaces?	ΠY	□N		
B. I	Do the plans clearly depict all required accessible EVCS features for the disabled?	□Y	□N		
	Do the plans identify the correct number and type of accessible EVCS stalls required in accordance with Table 11B-228.3.2.1?	□Y	□N		
	2) Do the plans detail compliance with the accessible EVCS features required by 11B-812 and Figure 11B-812.9?	ΠY	Пи		
es:	This criteria is intended for an expedited EVCS permitting process. If any items are checked NO, please revise plans to fit within the eligibility checklist; otherwise the permit application may go through the standard plan review and approval process. Plan review commences the day after submittal with up to 3 business days for qualifying expedited projects and up to 10 business days for all other EVCS projects.				
	Electrical plans shall be completed, stamped and signed by a California Licensed Electrical contractor.	ctrical E	nginee		
	EVCS project review is limited to health and safety requirements found under local, sto law. EVCS permit approval is not subject to approval of an association (as defined in the Civil Code).				
ect	Address:				
olico	ant Signature:				
olico	ants Printed Name:				
	ctor's License Number and type:				